

**“PEDESTRIAN CROSSING IMPROVEMENTS
NORTH INDIAN CREEK DRIVE FROM CHURCH STREET TO
ROGERS STREET”**

3/19/2019

**RESPONSE TO QUESTIONS
SPLOST 04 A**

The following are responses (in red) to questions received from prospective bidders:

Question #1: Could you please provide the name of the manufacturer of the proposed bricks on the medians?

Response: Brick pavers shall have herringbone design pattern; brick type – Belden Clay Pavers; Regimental Red A; 2 ¼ x 4 x 8